

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Sri Sanjay Kumar, Lab Assistant

(Name of Officers with designation) from P.H. Division, Begusarai PHED

inspected the Mount Litera Public School, ulao, Begusarai

(Name & Address of the school) on 05.06.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. WQ/01/2007-2025-4423 dated 09.06.2025

of District Level Water Testing Laboratory (PHED Lab) certified that


the Mount Litera Public School, ulao Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 6 month



To Mount Litera Public School

ulao, Begusarai
(Name & Address of the Institution)

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : P.H.E.D., Begusarai

ASSISTANT ENGINEER

P.H. Sub-division, Begusarai

Sri Manikant Kumar

A.E. Begusarai

GOVERNMENT OF BIHAR
P. H. Division , Begusarai, Toghra
DISTRICT LEVEL DRINKING WATER TESTING LABORATORY, BEGUSARAI.

Report No. :- WQ/01/ 2007 -2025 -4423 **Dt.** 09.06.2025

Date of Sampling -05.06.2025

Ref No -MLPS/BGS/24-25/

Sampl recieved on - 05.06.2025

Agency :- Mount Litera Public School, Ullao

Source of Sample :- Boring

Type Of Sample:- Treated Water Sample

Sample Collected by - Sri Deepak Kumar

PHYSICO-CHEMICAL TEST REPORT

Sl. No.	Location	Physico - Chemical Parameters (mg/l) ppm												
		pH	Turbidity	Conductivity	TDS	Total Hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Arsenic	Fluoride
1	Mount Litera Public School, Ullao, Begusarai	7.6	0.63	172	186	254	56	17	55	220	0.44	5	BDI	0.64
Desirable Limit*		6.5-8.5	5 NTU	-	500mg/l	300mg/l	75mg/l	30mg/l	250mg/l	200mg/l	1.0mg/l	45mg/l	0.01mg/l	1.0mg/l
Permissible Limit* in absence of alternate source		NR	NR	-	2000mg/l	600mg/l	200mg/l	100mg/l	1000mg/l	600mg/l	NR	NR	NR	1.5mg/l

Note:-

* (1) Drinking Water Specification 2ND Revision -IS:10500:2012,

* (2) BDL = Below Detection Limit,

* (3) Testing Methods are taken by APHA 20th Edition.

* (4) NR = No Relaxation

Lab Incharge
P. H. Division, Begusarai
District Level Testing Laboratory
Begusarai

09.06.25

Mount Litera Public School

ATTESTED

[Signature]

[Signature] Manager